

Corrosion and corrosion mitigation in pressurized water reactors

M. Helie

► To cite this version:

M. Helie. Corrosion and corrosion mitigation in pressurized water reactors. Conference invitee Universite de Pekin et Centre de recherches nucleaires de Suzhou, Mar 2018, Pekin, China. cea-02339324

HAL Id: cea-02339324 https://cea.hal.science/cea-02339324

Submitted on 14 Dec 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés. DE LA RECHERCHE À L'INDUSTRIE



CORROSION AND CORROSION MITIGATION

IN PRESSURIZED WATER REACTORS

M. HÉLIE

www.cea.fr

DE LA RECHERCHE À L'INDUSTR

NUCLEAR CORROSION SPECIFICITY & CHARACTERISTICS





Diversity







Absolute necessity to confine radioactive or contaminated products and materials

- Integrity of confinement barriers
- Decontamination and treatment of effluents
- Precautions during handling and storage



Containers for compacted ILW



Materials

From unalloyed steel to passive alloys (Fe, Ni, Ti base alloys)

Environments

Aqueous, from deionized to sea water From ambient to high temperature



Corroded steel rebars in concrete structure



Crack in steam generator tubing

Solicitations

Chemical, mechanical, thermal, radiolytic, bio-chemical ...

DE LA RECHERCHE À L'INDUSTR

Cea

DIVERSITY OF METALLIC MATERIALS IN A PWR



DE LA RECHERCHE À L'INDUSTRIE



DIVERSITY OF CORROSION PHENOMENA IN A PWR

Events linked to corrosion and safety (IRSN survey, 2010, French PWRs)





Predominant mechanisms

Flow Accelerated Corrosion FAC) Stress Corrosion Cracking (SCC)

Corrosion phenomena leading to reactor shutdown (R. Killian, 1995-2005 – worldwide survey)



Predominant mechanisms

Flow Accelerated Corrosion (FAC) Stress Corrosion Cracking (SCC)

DE LA RECHERCHE À L'INDUSTR

CORROSION AND CONFINEMENT BARRIERS





Fuel elements: the corrosion of zircaloy cladding is the limiting factor for residence time

Primary circuit: vessel resistance is linked to irradiation damage whereas SCC affects steam generator tubing



Reactor building: evolution of concrete and corrosion of rebars

Cea corrosion of zirconium alloy



Light Water Reactor Nuclear Fuel

Immersed in water in reactor core, Zr alloy cladding undergoes hydriding and uniform corrosion on its outer diameter, and iodine SCC on its inner diameter



After A. Motta

DE LA RECHERCHE À L'INDUSTRI

Cea zircaloy: Uniform Corrosion in Primary Medium



In primary conditions, the corrosion reaction is as follows:

 $Zr + 2H_2O \rightarrow ZrO_2 + 2(1-w)H_2$ (in water) + 2wH₂ (in alloy)

w = fraction of H_2 absorbed by the alloy

Progressive buildup of oxide layer Hydriding of the alloy



Schematic of zircaloy corrosion showing pre-transition, transition, and post transition in the cyclic oxidation process

After P. Bouffioux & B. Cheng

M. HÉLIE - National Center for Materials Service Safety

MITIGATION OF ZIRCONIUM ALLOY CORROSION

Replacement of Zircaloy-4 alloy with M5™ alloy



Zircaloy-4 and M5[™] oxidation kinetics. Autoclave tests in water with 10 ppm Li and 650 ppm B at 360°C. The kinetics appear as cyclic. M5[™] oxidation rate, the slowest on the average, displays the highest transition thickness

Cea Alloy 600: UNIFORM CORROSION IN PRIMARY MEDIUM

- Internal layer made of chromium oxide and small grains of chromium enriched spinel (Fe, Ni)(Cr, Fe)₂O₄
- External layer of nickel ferrite crystallites (NiFe₂O₄)



Consequences

- Oxide dissolution. Activation Ni ⁵⁸Co ⁶⁰Co in the core : Dose rate increase
- Intergranular oxidation selective chromium oxidation

Mitigation

PH adjustment to minimize oxide solubility. Zn addition to replace Ni in oxide ?

M. HÉLIE - National Center for Materials Service Safety _ Beijing January 2018 | PAGE 12/38

CORROSION IN PRIMARY

Mechanism

Primary water leaks **boric** acid concentration **boric** local pH decrease

Materials concerned

Low alloy steel bolts, primary pumps, steam generator and pressurizer manholes, valves, vessel head and vessel flanges, vessel itself in case of important spilling



Bolts corroded by boric acid

M. HÉLIE - National Center for Materials Service Safety

BOLTING STEELS CORROSION: MITIGATION



 250° C) and of nickel base alloys (H₃BO₃ 27wt% at 100°C)



Boric acid deposit due to leaks





Nozzle 3 with insulation removed and shielding installed 03-16-02

South Texas (USA)

Vessel bottom

David Besse (USA)

Vessel head

DE LA RECHERCHE À L'INDUSTRIE

CARBON STEEL CORROSION IN BORIC ACID DEPOSIT



Nickel base alloys

- Primary side : Primary Water SCC (PWSCC Coriou effect)
- Secondary side : InterGranular SCC (IGSCC)
- Stainless steel
 - Primary side (SCC)
 - Irradiation Assisted SCC (IASCC)
 - SCC under heat insulator (external surface)

□ Other alloys prone to SCC

- Brass (vapor or liquid polluted with NH₃ or sulfide) in condensers
- Low alloy or carbon steel for bolting and auxiliary circuits (sodium hydroxide, nitrates, chlorides, H₂S)
- Titanium in condensers (cathodic potential (H₂ embrittlement), hot medium with chloride)

STRESS CORROSION CRACKING IN PWRS



Intergranular Cracking



Alloy 600, SG tubing, primary water

Transgranular Cracking



17-4 PH steel, valve rod, high temp.

DE LA RECHERCHE À L'INDUSTRI

DIFFERENT STAGES OF STRESS CORROSION CRACKING



- (1) Importance of initial conditions
- (2) Preparatory phase (incubation)
- (3) Initiation phase followed by slow (4) and rapid propagation (5)

PREFERENTIAL POTENTIAL DOMAINS FOR SCC

Zones of relative "instability" of protective layers

Systems with poor ability to passivate cracking in the active/passive transition

Systems with strong ability to passivate critical cracking potential



CONSEQUENCES OF ALLOY 600 PWSCC

Replacement of Steam Generators with Alloy 600 MA tubing by Steam Generators with Alloy 600 TT or Alloy 690 tubing



DE LA RECHERCHE À L'INDUSTRI



CONSEQUENCES OF ALLOY 600 PWSCC



Replacement of a Steam Generator

Since 1998, AREVA has carried out more than 80 steam generator replacements, covering half of the market in the United States

M. HÉLIE - National Center for Materials Service Safety

MITIGATION OF ALLOY 600 PWSCC (OTHER THAN SG TUBING)

Replacement of Alloy 600 components with Alloy 690

- Pressurizer instrumentation nozzles
- Vessel head nozzles
- Steam Generator divider plates



DE LA RECHERCHE À L'INDUSTR

SCC MITIGATION AT THE TUBE-TUBE SHEET INTERFACE





- Two-step rolling allowing a smoother transition
- Shot peening of the tubes
- Rolling all along the tube sheet to suppress the crevice and limit the sludge pile

SCC AND DENTING MITIGATION AT THE TUBE-TUBE SUPPORT PLATE INTERFACE

- Accumulation of corrosion products at the interface causing stresses
 - Changing phosphate treatment (hideout problems) to AVT
 - Evolution of tube support plate geometry

Evolution of TSP geometry

(a) Drilled hole

(b) Egg crate

(c) Broached trefoil

(d) Broached quatrefoil



COO IASCC OF STAINLESS STEEL VESSEL INTERNALS



PWR vessel internals



Sinergy factors involved in IASCC



IASCC on an internal bolt of the French CPO series

MITIGATION OF IASCC IN VESSEL INTERNALS

Crevice around the bolt shank

- Local boiling due to γ heating of the bolt
- LiOH, H₃BO₃ and oxidizing species concentration

Drilling of a flow hole to suppress local crevice conditions



FLOW ASSISTED CORROSION (FAC)

FAC is a chemical and thermohydraulic degradation (not mechanical, not erosion)

Conditions of occurrence

- Unalloyed steels covered with a passive oxide layer (magnetite)
- In contact with high flow rate water or wet vapor
- No FAC in dry vapor

Chemical stationary conditions

Corrosion rate = Rate of oxide layer dissolution Rate of oxide layer dissolution inversely proportional to [M^{z+}] at the interface metal - solution

O No water flow [M^{z+}] ≈ saturation [Imp] Low Corr. rate [Imp] NO FAC

Itigh water flow I [M^{z+}] ≈ 0 High Corr. rate FAC

DE LA RECHERCHE À L'INDUSTRI

DOMAIN OF FAC OCCURRENCE



Cerror Fac in PWR – SURFACE MORPHOLOGY

Monophasic fluid (liquid water)

Bugey 5: Valve Horse shoe pits

SEM view of the surface

Micrographic cut

Diphasic fluid (wet vapor)

Bugey 2: Tubing Tiger stripping

Internal surface of the corroded tube



Cea MAJOR ACCIDENTS CAUSED BY FAC

□ 1986: SURRY 2 – 900MW PWR

- Consequences: 4 dead, 4 severely injured
- □ 1995: PLEASANT PRAIRIE 1 600MW Coal Plant
 - Consequences: 2 dead
- **2004: MIHAMA 3 780MW PWR**
 - Consequences: 5 dead, 6 severely injured



Surry 2: blow up of a 18" elbow



Pleasant Prairie 1: blow up of a straight line after a "T"



Mihama 3: blow up of a 22" straight line

FACTORS INFLUENCING FAC: WATER CHEMISTRY

pH has an important influence since it affects the solubility of metallic elements



Increasing pH decreases FAC

FACTORS INFLUENCING FAC: WATER CHEMISTRY

O₂ content has an important influence on FAC since it affects the oxide nature and properties

- Increasing O₂ content decreases FAC
- No FAC above 5 ppb O₂



Deal Factors Influencing Fac: Chromium Content

- Cr content has an important influence on FAC since it affects the oxide nature (formation of Fe₂CrO₄ of poor solubility)
 - Increasing Cr content decreases FAC
 - No FAC above 1% Cr whatever the temperature





Objective : to predict wall thickness loss due to FAC in order to be able to replace a component before rupture

Prediction based on :

- Physicochemical model
- Laboratory experiments
- In service data (real time monitoring of selected portion of circuits) to adjust the results
- Database involving results of all affiliated utilities in the world

2 MONITORING FAC: THE BRT CICERO™ CODE

□ Example of result given by BRT CICERO™ on a portion of circuit



M. HÉLIE - National Center for Materials Service Safety _ Beijing January 2018 | PAGE 36/38



- □ The use of BRT CICERO[™] is mandatory for the 58 French PWRs by decision of the Nuclear Safety Authority (ANS)
- Also used by Daya Bay and Ling Ao plants in China

□ Also used by Koeberg plant in South Africa

THANK YOU FOR YOUR ATTENTION

Commissariat à l'énergie atomique et aux énergies alternatives Centre de Saclay | 91191 Gif-sur-Yvette Cedex T. +33 (0)1 69 08 54 83 | F. +33 (0)1 69 08 15 86

Etablissement public à caractère industriel et commercial RCS Paris B 775 685 019

Direction de l'énergie nucléaire Département de physico-chimie Service de la corrosion et du comportement des matériaux dans leur environnement Laboratoire d'étude de la corrosion aqueuse