



HAL
open science

Is it possible to measure Sr-90 in radioactive waste without harmful chemical reagents?

Céline Gautier, Emilie Baudat, Hector Bagàn, Alex Tarancón Sanz, Christèle Colin, Elodie Laporte, Pascal Fichet

► To cite this version:

Céline Gautier, Emilie Baudat, Hector Bagàn, Alex Tarancón Sanz, Christèle Colin, et al.. Is it possible to measure Sr-90 in radioactive waste without harmful chemical reagents?. 14th International Symposium on Nuclear and Environmental Radiochemical Analysis, Sep 2022, York, United Kingdom. cea-03782553

HAL Id: cea-03782553

<https://cea.hal.science/cea-03782553>

Submitted on 23 Sep 2022

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Is it possible to measure Sr-90 in radioactive waste without harmful chemical reagents?

*Céline Gautier*¹, Emilie Baudat¹, Hector Bagán², Alex Tarancón², Christèle Colin¹,
Elodie Laporte¹, Pascal Fichet³*

(1) Université Paris-Saclay, CEA, Service d'Études Analytiques et de Réactivité des Surfaces, 91191, Gif-sur-Yvette, France.

(2) Department of Chemical Engineering and Analytical Chemistry, University of Barcelona, Martí i Franqués, 1-11, ES-08028, Barcelona, Spain.

(3) CEA, DES/DDSD/DFDE/SGOF, Building 611, 91191, Gif-sur-Yvette, France.

**celine.gautier@cea.fr*

Sr-90 is, with Cs-137, one of the main radioactive fission product occurring in nuclear power plants in terms of abundance proportion. This radionuclide can thus be present in significant amount in spent nuclear fuel or in radioactive waste from nuclear reactors. In the context of the increase of the number of decommissioning and dismantling operations in nuclear facilities, a reliable and rapid determination of Sr-90 is of prime interest for the characterization of all types of radioactive waste (effluents, ion exchange resins, concretes, sludges...).

Sr-90 has a half-life of 28.8 years and emits beta particles of relatively high energy (maximum energy of 546 keV). It disintegrates into Y-90 which is also a pure β -emitter (maximum energy of 2280 keV) with a half-life of 2.67 days. Sr-90 needs to be purified from interfering analytes through selective radiochemical separations before any reliable detection. It can be directly measured or indirectly evaluated from Y-90 growth. Both radionuclides are often measured by gas flow proportional counting and liquid scintillation counting (LSC). The separation yield is determined from stable strontium carrier by inductively coupled plasma (ICP) techniques or gravimetry.

Two main radiochemical methods for Sr-90 determination are generally implemented¹: Sr precipitation in highly concentrated nitric acid or extraction chromatography on Sr-resin[®]. Both procedures are robust and selective to provide accurate measurement of Sr-90 in radioactive samples. However, they involve the use of harmful chemical substances, respectively fuming nitric acid and liquid scintillation cocktails for LSC detection. Both reagents are in the scope of European REACH regulation and have to be removed from use as much as possible.

The purpose of this presentation is to demonstrate the feasibility of accurate Sr-90 measurement in radioactive waste without the use of toxic chemical reagents. The presentation will first focus on the optimization of a precipitation method by applying a design of experiments methodology². The implemented strategy induces the replacement of fuming nitric acid (above 82 % concentration) by concentrated nitric acid (69 % concentration) while maintaining high separation yield and improving the selectivity towards calcium which is the main interfering analyte of this method. Secondly, the presentation will deal with the implementation of plastic scintillation resin³ (noted PS resin) to avoid the use of liquid scintillation cocktails. A method based on a PS resin selective towards Sr was optimized so as to achieve high decontamination factors towards interfering radionuclides, in particular Pu-241 β -emitter. For both developed purification methods, the validation step is performed by comparing the results obtained on different types of radioactive waste

(effluents, concretes and sludges) with the ones obtained with the reference method of the laboratory based on fuming nitric acid. The selectivity of both methods is also evaluated by checking Y-90 growth (see Figure 1).




Figure 1: Y-90 growth curve from Sr-90 obtained with plastic scintillation resin selective towards Sr

References

- ¹Hou et al., Anal Chim Acta (2011) 608 (2008):105-139.
- ²Baudat et al., J. Radioanal. Nucl. Chem. (2021) 328:637-650.
- ³Bagán et al. Anal Chim Acta (2011) 686:50-56.