

Corrosion behavior of a AISI-316 stanless grade type in nitrogen environment for a sodium-gas heat exchanger

S. Bosonnet, K. Ginestar, D. Gosset, F. Barcelo, B. Duprey, L. Martinelli

▶ To cite this version:

S. Bosonnet, K. Ginestar, D. Gosset, F. Barcelo, B. Duprey, et al.. Corrosion behavior of a AISI-316 stanless grade type in nitrogen environment for a sodium-gas heat exchanger. HTCPM 2016 - 9th International Symposium on High-Temperature Corrosion and Protection of Materials, May 2016, Les Embiez, France. hal-02441952

HAL Id: hal-02441952 https://cea.hal.science/hal-02441952v1

Submitted on 16 Jan 2020 $\,$

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Corrosion Behavior of a AISI-316 Stainless Steel Grade Type in Nitrogen **Environnment for a Sodium Gas Heat Exchanger** S. BOSONNET^a, K. GINESTAR^a, D. GOSSET^b, F. BARCELO^b, B. DUPREY^a, L. MARTINELLI^a

^aDen-Service de la Corrosion et du Comportement des Matériaux dans leur Environnement (SCCME), CEA, Université Paris-Saclay, F-91191, Gif-sur-Yvette, France. ^b Den-Service de Recherches Métallurgiques Aplliquées(SRMA), CEA, Université Paris-Saclay, F-91191, Gif-sur-Yvette, France.

CONTEXT: Generation IV for nuclear power plants: Energy Conversion System for ASTRID project

Energy Conversion in nuclear plants uses to be operated by steam generators. To eliminate the Sodium-Water Reaction Risk , an alternative option of Energy Conversion System operating with gas is developped in the framework of ASTRID project. Heat of the nuclear reaction is recovered by a secondary sodium system and transferred to a 3rd circuit containing **Nitrogen** and maintained at 180 bar to make the turbine rotate.

In Sodium-Gas-Energy Conversion System, heat transfer takes place inside modulus comprising 2 channels networks: one for nitrogen and the other one with larger section for sodium flowing. Each channels are separated by a wall of 2 mm thick for good thermal conductivity. Selected material : AISI- 316 SS grade Working conditions in the modulus:

Na: P ~1bar; Inlet θ =530°C and Outlet θ =330°C N₂: P=180 bar ; Inlet θ =315°C and Outlet θ =515°C

OBJECTIVES

Good performance of the ECS has to be guaranteed for **30 years** \rightarrow Compatibility of the 316L with N₂ environment at 515°C and 180 bar has to be checked.

Stability of main nitrides as a function of P_{N_2} . Activity values of Fe, Cr, and Ni are the molar fraction in 316L. At 515°C and 180 bar N₂, CrN and Cr₂N are potentially If oxygen is present, competition between nitridation and oxidation may occur. **Oxidation susceptibility** to take into account.

Considering that both P_{N_2} and P_{O_2} decrease in serial corrosion layers from external to bulk material, thermodynamic diagram suggests 3 scenarios:



Main nitrides Ellingham diagram Thermodynamic data from HSC database.

Expected phenomenon : •Nitrogen diffusion onto the surface

- \rightarrow nitriding layers;
- No continuous layer
- \rightarrow internal nitridation (in the matrix). Severity of damages depends on affected thickness.

 \rightarrow Few relevant data within the ECS conditions : they concern other environment than pure N_2 (NH₃, N_2 /air or complex atmospheres), other materials (Nibased alloys) and higher temperature.



Thermodynamic diagram for Fe19CCr11Ni at 515°C and 180 bar. Obtained with FactSage.

• Cr_2O_3 internal oxidation



Literature do not rule on the absence of damaging on 316L in ECS conditions. Experimental program set up to acquire long term corrosion kinetics (up to 5000 hours)

EXPERIMENTAL



С	Si	Mn	Р	S	Cr	Мо	Ni	Ν	Со	Fe
0,022	0,335	1,286	0,034	0,002	16,543	2,044	10,093	0,048	0,132	bal



1000 h in 4 cycles of 100+200+200+500 hours

- After static under pressure tests, surfaces are heterogeneous : nanometric films and micrometric layers (with different morphology depending on the number of cycles). They are homogeneous for all dynamic tests.
- 2 kinds of oxides form on surface during static test : spinel and chromia containing Mn while main chromia in dynamic test.
- In both cases a new c.c phase in underlying metal (with Fe and Mo).

Corrosion phenomena is due to **oxidation** Under N₂ flow at 1 bar at 515°C, the oxide film is compact and uniform and seems to

corrosion kinetics but those crystallites change with long period cycles.

PROSPECTS

In static conditions, gas content is gradually O_2 depleted and the consequences of this depletion will be studied to understand mechanisms in **non-stationary environment**.

Elemental EDS- X mapping

600 nm